



Date: 27.02.2023

No. SH/PMC/BBMP/ BD / / 2023-24

To,
The Executive Engineer
Byatarayanapura Division,
Bruhat Bangalore Mahanagara Palike,

Dear Sir,

Sub: Package No. 02- (Consists of 5 works) Improvements to Roads and Drains
in Coffee Board Layout Ward no: 07 Bytarayanapura.

In reference to the above subject, this is to bring to your kind notice that we have scrutinized the
1st and Part bill submitted by **M/s Sri Venkateshwara Constructions, Prop . Sri Sambashiva**
towards the above said work and arrived at an amount of **Rs 2,49,15,091.00/- (Rupees Two Crore Fourty Nine lakhs Fifteen thousand and Ninty one Rupees only)**. This work has been completed satisfactorily.

This is for your kind information.

Thank you and assuring you the best of our Services at all the times.

For M/s Shiprama Consulting Engineers Pvt Ltd Bangalore





SHIPRAMA CONSULTING ENGINEERS PRIVATE LIMITED

(MECHANICAL TESTING LABORATORY DIVISION)

ISO 9001:2015 Certified Company

QUALITY CONTROLE ABSTRACT (AS PER MORTH -V REVISION)

NAME OF WORK: Package-2 - Improvements to Roads and Drains of Coffee Board Layout In Ward no: 07 Bytarayanapura.

NAME OF AGENCY: M/s Sri Venkateshwara Constructions, Prop.Sri Sambashiva,

BILL:1st & Part Bill

SL NO	DESCRIPTION OF ITEMS	TEST	TEST UNITS	TEST PER QTY	UPTO DATE QTY	NO.OF SAMPLE CONDUCT FOR TEST	NO.OF SAMPLE CONDUCT FOR TEST
	For Asphalt Work						
1	Wet Mix Macadam				1415.99 Cum		
a		Aggregate Impact Value-IS 2720 (Part-4)- 1985 RA 2015, MORTH Table 400-13	Days	one source		1	1
b		Gradation- IS 2720 (Part-4)- 1985 RA 2015, MORTH Table 400-13	Days	Seven source		7	7
c		ATTERBERG LIMITS-IS:2720 (part 5)-1985 RA 2015, MORTH Table 400-13	Days	Seven source		7	7
d		Shape test-IS:2386(part 1)- 1963 RA 2016, MORTH Table 400-12	Days	Four source		4	4
2	Dense Bituminous Macadam				307.82 Cum		
a		Bitumen Content-IS 2720 (Part-4)- 1985 RA 2015, AASHTO T 164 & AASHTO T 30 & MORTH	Days	one source		1	1
b		Gradation -IS 2720 (Part-4)- 1985 RA 2016, MORTH Table 500-10	Days	one source		1	1
c		Impact Value -IS 2386 (Part-4)- 1963 RA 2016, MORTH table 500-10	Days	one source		1	1
d		Quality of Binder -IS 73 -2013	Days	one source		1	1
e		Shape test- IS:2386(part 1)- 1963 RA 2016, MORTH Table 400-13	Days	one source		1	1
f		Specific Gravity & Water Absorption -IS 2386 (Part-4)- 1963 RA 2016, MORTH Table 500-10	Days	one source		1	1
g		Stability Of Mix-MORTH Table 500-11	Days	one source		1	1
3	Bituminous Concrete				1003.57 Cum		
a		Bitumen Content-IS 2720 (Part-4)- 1985 RA 2015, AASHTO T 164 & AASHTO T 30 & MORTH	Days	Three source		3	3
b		Gradation -IS 2720 (Part-4)- 1985 RA 2020, MORTH Table 500-17	Days	Three source		3	3
c		Impact Value -IS 2386 (Part-4)- 1963 RA 2020, MORTH Table 500-17	Days	Three source		3	3
d		Quality of Binder -IS 73 -2013	Days	Three source		3	3
e		Shape test- IS:2386(part 1)- 1963 RA 2016, MORTH Table 500-17	Days	Three source		3	3
f		Specific Gravity & Water Absorption - IS 2386 (Part-4)- 1963 RA 2016, MORTH Table 500-17	Days	Three source		3	3
		Stability Of Mix-MORTH Table 500-17	Days	Three source		3	3



048, 8th Cross Extension, Gangubai Layout, S.M. Vishveshwaraiah Layout, Near Gidadakonenahalli

Bangalore-560091 Mob:9886218888 | 29554444 | Email: shiprama888@gmail.com |

Kodigehalli Sub Division
BBMP, Bangalore